

OFFICE OF THE CORPORATION OF THE CITY, NAGPUR  
(FIRE & EMERGENCY SERVICE)

Chhatrapati Shivaji Maharaj Prashashkiya Bhawan, Mahanagar Palika, Civil Lines, Nagpur - 440 001

Ph No. : 0712-2567778

Fax No. : 0712-2561581

No. FES/198/CFO

Date : 15/05/2026

To,

The Secretary,  
Shree Shaishnik & Samajik Bahuudeshiya, Sanstha  
225 Ramdaspath, Nagpur.

Sub : Compliance Certificate.

Ref : 1) Recommendation Letter No. FES/450/CFO

2) Your Application Dated 04/05/2026 for Compliance Certificate.

Certified that the Educational building having height 10.71 mtr. Ground to 1 Floors Right Ground Floor and built up area of 4579.00 Sq. Mtr. belonging to The Secretary, Shree Shaishnik & Samajik Bahuudeshiya Sanstha, Kh. No. 201 Mouza- Lendra, Central Bazaar Road, Opp. Krushikunj Ramdaspath, Nagpur, has complied with the fire prevention and safety measures in accordance with the fire prevention and life safety measures act 2006 (herein after referred as said act.)

This compliance certificate is issued on the basis of the inspection report of Deputy Chief Fire Officer, Kalamna Fire & Emergency Service dated 12/05/2026 and certificate "A" (as per the provisions of said act 2006) dated 10/05/2018 by Licensed Agency M/s Oyster Infra-con Pvt. Ltd, (License No. MFS-LA/F-0192, LA/D-0154, LA/P-0022) regarding the compliance of the fire prevention and life safety measures on following conditions as prescribed in the said act 2006.

1. Under the Sub section (3) of section 3 it is the responsibility of the owner or the occupier as the case may, shall furnish to the Chief Fire Officer a certificate in a prescribed form twice in a year i.e. in the month of January and July regarding maintenance of fire prevention and life safety measures in good repair and efficient condition as specified in sub section (1).
2. Under sub section (4) of section 3, No person shall tamper with alter remove or cause any injury or damage to any fire prevention and life safety equipment installed in any such building or part thereof or instigate any other person to do so.
3. The undersigned reserve the right to add/delete or amend any recommendation deemed fit during future inspection and due to us gradation of fire fighting monitoring system of this department in interest of life safety.
4. Any additional construction or change in use of the building or part there of shall render this certificate cancelled and invalid.
5. The owner or occupier shall pay annual fee at the rate 1% of the minimum fees specified in schedule II as per section 11(1) and 14(4)

  
NAGPUR MUNICIPAL CORPORATION

Chief Fire Officer

Fire & Emergency Service, Mpl.  
Corporation, Nagpur

Copy to : 1) The Building Engg. (ADTP)/  
N.I.T./N.M.C/NMRDA, Nagpur.  
2) Deputy Chief Fire Officer  
Kalamna Fire & Emergency Service.